



Mariposa County Environmental Health

5100 Bullion Street
 Post Office Box 5
 Mariposa, California 95338
 (209) 966-2220 FAX (209) 966-8248



Water Quality Monitoring Schedule Vacation Rentals- No Food Service

Chemical – Section/Table	Maximum Contaminant Level (mg/L)	Frequency
Nitrate (Nitrogen)	10	1 time only Depending on results additional testing may be required Sample must be no more than 1 year old
Bacteriological Examination		1 time only provided sample is free of bacteria Sample must be no more than 90 days old

Note: All water analyses are to be performed by laboratories certified by the State of California. A list of certified laboratories is available from the Mariposa County Environmental Health Division. Advise the laboratory to send copies of lab reports to:

Mariposa County Public Health
 Environmental Health Division
 Post Office Box 5
 Mariposa, CA 95338

Water samples which are found to contain coliform organisms are to be reported by the lab immediately to Environmental Health at (209) 966-2220.