



# Mariposa County Health Department

Eric Sergienko, MD, MPH, Director

Community Health Section  
5085 Bullion Street  
Post Office Box 5  
Mariposa, California 95338  
(209) 966-3689 FAX (209) 966-4929

Environmental Health Section  
5100 Bullion Street  
Post Office Box 5  
Mariposa, California 95338  
(209) 966-2220 FAX (209) 966-8248



**Public Health**  
Prevent. Promote. Protect.

## Water Quality Monitoring Schedule Vacation Rentals- No Food Service

Chemical – Section/Table	Maximum Contaminant Level (mg/L)	Frequency
Nitrate (Nitrogen)	10	1 time only Depending on results additional testing may be required  Sample must be no more than 1 year old
Bacteriological Examination		1 time only provided sample is free of bacteria  Sample must be no more than 90 days old

Note: All water analyses are to be performed by laboratories certified by the State of California. A list of certified laboratories is available from the Mariposa County Health Department. Advise the laboratory to send copies of lab reports to:

Mariposa County Health Department  
Environmental Health  
Post Office Box 5  
Mariposa, CA 95338

Water samples which are found to contain coliform organisms are to be reported by the lab immediately to the Health Department at (209) 966-2220.